

Misc Pipe Markers

Product Images



Description

Miscellaneous Pipe Markers successfully identify the contents and flow of pipes allowing workers to safely trace process problems and get production back in line faster.

- Pipe Markers are to be located adjacent to valves, junctions, bulkheads, service appliances & wall penetrations.
- Markers must be spaced no more than 8m apart with the exception of long, uninterrupted straight runs of external services where spacing shall not exceed 50metres.

- Comes in a packet of 10.
- Use in conjunction with our Supplementary Safety Markers (sold separately) for instances where additional information about the contents of a pipe is required.
- Bronson Safety Pipe Markers comply to AS 1345-1995 & AS 2700 1996.

Additional Information

Label Type	Pipe & Valve Marking
------------	----------------------

Product Options

Label Legend:	Effluent
	Product
	Sewerage
	Vent
	Waste
Label Size:	30mm x 380mm
	50mm x 400mm