Fire Fighting Water Pipe Markers (Pack of 10)

Product Images

Description

Waste Pipe Markers successfully identify the contents and flow of pipes allowing workers to safely trace process problems and get production back in line faster.

- Pipe Markers are to be located adjacent to valves, junctions, bulkheads, service appliances & wall penetrations.
- Markers must be spaced no more than 8m apart with the exception of long, uninterrupted straight runs of external services where spacing shall not exceed 50metres.
- Comes in a packet of 10.
- Use in conjunction with our Supplementary Safety Markers (sold separately) for instances where additional information about the contents of a pipe is required.
- Bronson Safety Pipe Markers comply to AS 1345-1995 & AS 2700 1996.

Click here to see our complete range of Pipe & Valve Markers.

Additional Information

Label Type	Pipe & Valve Marking

Product Options

Label Size:	30mm x 380mm
	50mm x 400mm